

Union County, Georgia

ADDENDUM # 1 **August 27, 2021** **Union County Facilities Additions/Renovations** **Project# UC-2021-02**

**This addendum is issued to change or clarify the proposal documents associated with the
Union County Facilities Additions/Renovations
Issued August 11, 2021**

List of Items Included in Addendum #1

1. Questions and Answers (attached)
2. Drawings (See Attached):
Item D.1. Revise Electrical Sheets E-002 and E-1.02 as shown
3. Specifications:
Item S1. Revise Section 10 2175- Phenolic Core Partitions
2.04 Characteristics
A. Change panel minimum 1/2" thick to 3/4" thick. All panels, doors and pilasters to be 3/4" thick.
2.05 Fabrication
B. Change to- Panels: Flush, formed of 3/4" solid phenolic panels.

**Note: A signed acknowledgement of this addendum must be received by the
Purchasing Agent attached to your response.**

Vendor Name: _____

Address: _____

Email: _____

Authorized Signature: _____ Date: _____

Name (Printed): _____ Title: _____

Question1:

Is there a designated pricing form to be used and signed?

Answer to Question 1:

No

Question 2:

Is a bid bond required for submission?

Answer to Question 2:

Yes

Question 3:

For the 20 page limit is this single sided?

Answer to Question 3:

No

Question 4:

Does this page county include cover/tabs/bidders certification, E-verify, contractors license?

Answer to Question 4:

No